

REPORT DOCUMENTATION PAGE			Form Approved OMB No. 0704-0188	
Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188), Washington, DC 20503.				
1. AGENCY USE ONLY (Leave blank)		2. REPORT DATE 03/01/77		3. REPORT TYPE AND DATES COVERED
4. TITLE AND SUBTITLE 420 GPM PILOT PLANT POWDERED CARBON FLOW VARIATION STUDY			5. FUNDING NUMBERS	
6. AUTHOR(S)				
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) ROCKY MOUNTAIN ARSENAL (CO.) COMMERCE CITY, CO			8. PERFORMING ORGANIZATION REPORT NUMBER 82161R01	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)			10. SPONSORING/MONITORING AGENCY REPORT NUMBER	
11. SUPPLEMENTARY NOTES				
12a. DISTRIBUTION / AVAILABILITY STATEMENT APPROVED FOR PUBLIC RELEASE; DISTRIBUTION IS UNLIMITED			12b. DISTRIBUTION CODE	
13. ABSTRACT (Maximum 200 words) THE PURPOSE OF THE POWDERED CARBON FLOW VARIATION STUDY WAS TO DETERMINE AND COMPARE THE CARBON BED HEIGHT SENSITIVITY FOR TWO DIFFERENT CARBON BEDS AT VARIOUS INFLUENT WATER RATES WITHOUT THE INFLUENCE OF A REPLACEMENT CARBON FEED RATE.				
<div style="text-align: right;">DTIC QUALITY INSPECTED 4</div> <div style="text-align: center; font-size: 2em; font-weight: bold;">19950223 027</div>				
14. SUBJECT TERMS WATER RATES, WATER SOURCES			15. NUMBER OF PAGES	
			16. PRICE CODE	
17. SECURITY CLASSIFICATION OF REPORT UNCLASSIFIED	18. SECURITY CLASSIFICATION OF THIS PAGE	19. SECURITY CLASSIFICATION OF ABSTRACT	20. LIMITATION OF ABSTRACT	

ROCKY MOUNTAIN ARSENAL
DENVER, COLORADO 80240

420 GPH PILOT PLANT POWDERED CARBON
FLOW VARIATION STUDY

Rocky Mountain Arsenal
Information Center
Commerce City, Colorado

Accession For	
NTIS CRA&I	<input checked="" type="checkbox"/>
DTIC TAB	<input type="checkbox"/>
Unannounced	<input type="checkbox"/>
Justification	
By	
Distribution /	
Availability Codes	
Dist	Avail and/or Special
A-1	

APPROVED:


JOHN P. BYRNE, COL, CMIC
Commanding

FILE COPY

1 MAR 77

420 GPH PILOT PLANT POWDERED CARBON FLOW VARIATION STUDY

1. Purpose - The purpose of the powdered carbon flow variation study was to determine and compare the carbon bed height sensitivity for two different carbon beds at various influent water rates without the influence of a replacement carbon feed rate.

2. Procedure

a. The chemical concentrations and their feed rates remained constant. The chemicals were injected with the agitator functioning.

b. The Erdlator was filled with influent well water through the downcomer.

c. Powdered carbon was introduced to the Erdlator through the downcomer.

d. The agitator and influent well water feed operations were continued until the carbon bed stabilized.

e. Various flow rates were introduced and maintained until a stable condition was established. Measurements were then made to obtain bed height.

g. Well water was transported in a truck tanker from the well location to Building 742. The water was unloaded from the truck and stored in 3,000 gallon storage tanks at the test site.

3. Test Conditions

a. Carbon bed composition -- a 20 pound and 30 pound bed of Hydro Darco C powdered carbon.

b. Influent water rates -- 1, 3, 5, 6, 7, and 7½ gpm.

c. Replacement carbon feed rate -- none.

d. Cationic solution -- 6 gm Catfloc/gal @ 25 CC/min feed.

e. Anionic solution -- 0.5 gm Hercufloc/gal @ 120 CC/min feed.

f. Water source -- water from wells PW 2 and 3.

420 GPH PILOT PLANT POWDERED CARBON FLOW VARIATION STUDY - Cont

4. Comments

a. The cationic and anionic solution concentrations and their feed rates were determined from previous runs as having demonstrated reliability and stability over the operating range of the experiment.

b. The 20 pound carbon bed displayed a uniform increase of bed height in relation to the change in water rate until the 5 gpm capacity was attained. At the 6 and 7 gpm water rate, the bed height increased rapidly, yet within the design operating parameters. Attempting to operate the water treatment plant above the design criteria revealed a drop in bed height of $2\frac{1}{2}$ " plus a turbid condition through the product water had set in, as shown at the $7\frac{1}{2}$ gpm water rate (Incl 1).

c. Similarly, the 30 pound carbon bed displayed a uniform increase of bed height in relation to the change in water rate, except the uniformity extended to the 6 gpm water rate capacity. At the 7 gpm water rate, the bed height increased rapidly, yet within the design operating parameters. Although the bed deterioration is less than the 20 pound carbon dosage while operating above the design criteria, a turbid condition existed, plus a bed height drop of $\frac{1}{4}$ " was noted at the $7\frac{1}{2}$ gpm water rate (Incl 1).

d. Bed Height Data (inches)

<u>Waterflow</u> <u>(gal/min)</u>	<u>Carbon Dosage</u>	
	<u>20#</u>	<u>30#</u>
1	15 $\frac{3}{4}$	17 $\frac{1}{4}$
3	18 $\frac{1}{4}$	20 $\frac{1}{4}$
5	18 $\frac{3}{4}$	21 $\frac{1}{4}$
6	20 $\frac{1}{4}$	21 $\frac{1}{4}$
7	20 $\frac{1}{2}$	27 $\frac{1}{4}$
7 $\frac{1}{2}$	17	27

5. Conclusions

a. Recommend operating the 420 gph pilot water treatment plant at 5 gpm. The 5 gpm water feed rate shows the most stable condition at the highest feed to operate the pilot plant.

420 GPH PILOT PLANT POWDERED CARBON FLOW VARIATION STUDY - Cont

b. The larger carbon dosage presents a more uniform carbon bed height change in relation to water rate modifications.

c. The carbon bed heights degenerate above the design criteria of 7 gpm water rate.

d. Since this test was primarily run to evaluate the relation of carbon bed height sensitivity to various influent water rates, no replacement carbon feed rate nor filtration efficiency were evaluated.

e. Extrapolation of this test data would indicate that it is doubtful the 10,000 gph Erdlator could process water in excess of its rated capacity and may, in fact, be operationally stable over extended periods at a maximum rate of 8,000 gph.

f. Further tests will be necessary to fully evaluate the maximum potential of the system.

1 Incl
as

PROCESS TECHNOLOGY

420 GPH FLOW VARIATION STUDY

